



**STATE OF HAWAII
OFFICE OF HAWAIIAN AFFAIRS
560 NORTH NIMITZ HIGHWAY, SUITE 200
HONOLULU, HAWAII 96817**

February 14, 2019

**REQUEST FOR QUOTE LAF 2019-18
INSTALLATION OF THREE (3) ELECTRICAL CIRCUITS
ADDENDUM No. 02**

AMENDMENTS TO ORIGINAL REQUEST FOR QUOTE

- 1) Item 2 on page 1 under the Scope of Work of the RFQ LAF 2019-18 reads:
 2. Securing, fastening, rough-in
 - a. Conduits can be strapped to existing uni-strut for part of the run;
 - b. Part of conduit run will be in sheet rock and above ceiling tiles; and
 - c. Conduits/outlets in kitchen area to be non-surface mount.

Item 2 on page 1 under the Scope of Work of the RFQ LAF 2019-18 is hereby amended to read as follows:

2. Securing, fastening, rough-in
 - a. Conduits can be strapped to existing uni-strut for part of the run;
 - b. Part of conduit run will be in sheet rock and above ceiling tiles;
 - c. Conduits/outlets in kitchen area to be non-surface mount; and
 - d. Walls must be patched and painted as well as the new conduit after electrical work is completed. **The OHA will provide the paint to the vendor.**

AMENDMENTS TO QUESTIONS & ANSWERS

- 1) Do the walls have to be painted?

Yes, the vendor needs to paint the wall. We may have the matching paint color in the storage but we will need to check. We can also provide the name of the matching paint color.

We have the paint in our storage. Therefore, we will be able to provide the paint to the vendor.

4) Is there an option to work on the weekends or at night?

It would need to be scheduled.

No, there is no longer an option to work on the weekends or at night. Work must be completed during working hours between 7:45 a.m. to 4:30 p.m.