



**STATE OF HAWAII
OFFICE OF HAWAIIAN AFFAIRS
560 NORTH NIMITZ HIGHWAY, SUITE 200
HONOLULU, HAWAII 96817**

March 16, 2022

**REQUEST FOR QUOTES (RFQ) NO. LLP 2022-028
GRAVEL MAINTENANCE & REPAIR SERVICES AT WAHIAWĀ LANDS**

**Addendum No. 1
Response to Questions**

1. Q: What kind of herbicide should be used to get rid of grass?

A: We recommend utilizing a systemic herbicide that will get to the root of the grass such as Roundup.

2. Q: What size rock should be used? What type of gravel is required?

A: We are requesting 5" - 6" minus surge rock. The gravel's primary function is to keep vehicle from tracking mud onto the road after leaving the property.

The foot path (30' by 4') from the Whitmore gate to the entrance of the easement road will require $\frac{3}{4}$ " gravel. The foot path goes through the gravel area in front of the bollard.



At the Kamananui Gate entrance, there is 8" – 9" gravel in the area in front of the gate (Dimensions 25' x 25'). We would like a layer of 5"-6" gravel to go over this area and fill in the gaps.



3. Q: Will OHA provide photos of the target areas that require gravel maintenance?

A: Yes, please review the photos provided in this Addendum.

4. Q: How deep (thick) do you want the gravel to be? How much gravel coverage is required?

A: There should be uniformed coverage across the current gravel areas. More rocks should be placed where is there gaps. A layer of new gravel shall be places on top of the old gravel.

Dimensions of gravel areas are as follows:

Whitmore Gate Gravel Area:

- 30' x 30' – The 30' x 4' footpath is within this area
- 15' x 25'
- 20' x 50'

Kamananui Gate Gravel Area

- 25' x 25' in front of gate
- 20' x 60' in back of gate

5. **Q: Will OHA be providing quantities, dimensions of target areas in order to get accurate bids in which all contractors are bidding on the same amount of work, material, equipment necessary, labor, etc.?**

A: Yes, please review question #4 of Addendum No. 1.

6. **Q: Is this a prevailing wage rate project? If so, is this a chapter 103 or chapter 104 project?**

A: No, this is not a prevailing wage project.